

Inspection No. \_\_\_\_\_  
Parcel # \_\_\_\_\_  
Inspection Fee \$35.00

**Town of Wilson**  
**5935 South Business Drive**  
**Sheboygan, WI 53081**

## **CLEAR WATER INSPECTION REPORT**

Date Requested: \_\_\_\_\_ Parcel # \_\_\_\_\_

Date Scheduled: \_\_\_\_\_ Time: \_\_\_\_\_

Special Access Instructions: \_\_\_\_\_

Requester's Name: \_\_\_\_\_ Phone # \_\_\_\_\_ Fax # \_\_\_\_\_

Owner's Name: \_\_\_\_\_

Address: \_\_\_\_\_

Billing Address: \_\_\_\_\_

The Wisconsin Administrative Code Comm. 82.36(3), and the Sanitary District Clearwater Ordinance Forbids The Discharge of Clear Water Into The Sanitary Sewer System.

---

**I Observed The Following Violations:**

- \_\_\_\_\_ 1. Your Sump Pump Is Connected Directly To The Sanitary Sewer.
- \_\_\_\_\_ 2. Your Sump Pump Is Cross-Connected To The Sanitary Sewer.(There Is A Tee In The Discharge Pipe, Which Leads To The Floor Drain.)
- \_\_\_\_\_ 3. The Floor Drain Is Connected To The Footing Tile, Roof Leader, Or Other.
- \_\_\_\_\_ 4. The Sump Pit Has A Bypass To The Floor Drain.
- \_\_\_\_\_ 5. The Discharge Piping On The Sump Pump Is Not Of Material Approved In Comm. 84.30 Of The State Plumbing Code. (PVC Or ABS Plastic, Copper, Galvanized, Steel, Cast Iron, Brass)
- \_\_\_\_\_ 6. The Downspouts Are Connected To The Sanitary Sewer Systems.
- \_\_\_\_\_ 7. Floor Drain(s) Non-Accessible At Time Of Inspection.
- \_\_\_\_\_ 8. One Or More Downspout Leaders Exist.

COMMENTS: \_\_\_\_\_

THE FOLLOWING CORRECTIONS MUST BE MADE NO LATER THAN \_\_\_\_\_

- \_\_\_\_\_ 1. The Cross-Connection To The Sanitary Sewer Must Be Removed And The Sump Pump Must Discharge To The Outside Of The Dwelling.
- \_\_\_\_\_ 2. You Must Remove Or Plug The Cross-Connection Of The Drain Tile To The Floor Drain. (Plugging The Cross-Connection Without Installing A Sump Pump May Result In Water Damage To The Foundation And Or Water Accumulating On The Basement Floor. We Recommend Installing A Sump Pit and Pump.)
- \_\_\_\_\_ 3. The Bypass From The Sump Pit To The Floor Drain Must Be Capped Or Plugged And The Bypass Piping Removed.
- \_\_\_\_\_ 4. The Discharge Pipe From The Sump Pump Must Conform To Comm. 84.30. (See #5 Above)
- \_\_\_\_\_ 5. The Downspouts Must Be Disconnected And/Or the Pipe Plugged with Cement Or Mortar.

IT IS THE OWNER'S RESPONSIBILITY TO CALL THE INSPECTOR FOR A REINSPECTION WHEN THE VIOLATIONS HAVE BEEN CORRECTED. AN ADDITIONAL \$35 FEE WILL APPLY. IF YOU HAVE ANY QUESTIONS PLEASE CALL THE TOWN AT 208-2390.

INSPECTION MADE BY: \_\_\_\_\_ DATED \_\_\_\_\_

VIOLATIONS CORRECTED ON: \_\_\_\_\_  
OWNER \_\_\_\_\_ DATED \_\_\_\_\_